



IECEx Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.: **IECEx KEM 09.0072X**

Page 1 of 4

Certificate history:

Status: **Current**

Issue No: 4

[Issue 3 \(2019-03-25\)](#)

[Issue 2 \(2014-04-03\)](#)

[Issue 1 \(2010-01-27\)](#)

[Issue 0 \(2009-12-15\)](#)

Date of Issue: 2022-10-28

Applicant: **Weidmuller Interface GmbH**
Klingenbergstrasse 16
32758 Detmold
Germany

Equipment: **NAMUR Pulse Isolator, Type ACT20X-.HDI-.SDO-...-S, Type ACT20X-.HDI-.SDO-...-P**

Optional accessory:

Type of Protection: **Ex i, Ex e, Ex n**

Marking: **Ex ec nC IIC T4 Gc**
[Ex ia Ga] IIC/IIB/IIA
[Ex ia Da] IIIC
[Ex ia Ma] I

Approved for issue on behalf of the IECEx
Certification Body:

R. Schuller

Position:

Certification Manager

Signature:
(for printed version)

Date:
(for printed version)

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting www.iecex.com or use of this QR Code.



Certificate issued by:

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands





IECEx Certificate of Conformity

Certificate No.: **IECEx KEM 09.0072X**

Page 2 of 4

Date of issue: 2022-10-28

Issue No: 4

Manufacturer: **Weidmuller Interface GmbH**
Klingenbergstrasse 16
32758 Detmold
Germany

Manufacturing locations: **Weidmuller Interface GmbH**
Klingenbergstrasse 16
32758 Detmold
Germany

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended

STANDARDS :

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

[IEC 60079-0:2017](#) Explosive atmospheres - Part 0: Equipment - General requirements
Edition:7.0

[IEC 60079-11:2011](#) Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"
Edition:6.0

[IEC 60079-15:2017](#) Explosive atmospheres - Part 15: Equipment protection by type of protection "n"
Edition:5.0

[IEC 60079-7:2017](#) Explosive atmospheres - Part 7: Equipment protection by increased safety "e"
Edition:5.1

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Report:

[NL/KEM/ExTR09.0087/04](#)

Quality Assessment Report:

[NL/DEK/QAR12.0052/08](#)



IECEx Certificate of Conformity

Certificate No.: **IECEx KEM 09.0072X**

Page 3 of 4

Date of issue: 2022-10-28

Issue No: 4

EQUIPMENT:

Equipment and systems covered by this Certificate are as follows:

NAMUR Pulse Isolators, for rail mounting, Type ACT20X-.HDI-.SDO-...-S or Type ACT20X-.HDI-.SDO-...-P are 24 V powered isolating barriers, interfacing "Namur" sensors or contacts located in an explosive atmosphere.

ACT20X-HDI-.SDO-...-S or ACT20X-HDI-.SDO-...-P are one channel versions.
ACT20X-2HDI-2SDO-...-S or ACT20X-2HDI-2SDO-...-P are two channel versions.

Ambient temperature range -20 °C to +60 °C.

Used models:

Type ACT20X-HDI-.SDO-RNO-S,
Type ACT20X-HDI-.SDO-RNO-P,
Type ACT20X-HDI-.SDO-RNC-S,
Type ACT20X-HDI-.SDO-RNC-P,
Type ACT20X-HDI-.SDO-S,
Type ACT20X-HDI-.SDO-P,
Type ACT20X-2HDI-2SDO-RNO-S,
Type ACT20X-2HDI-2SDO-RNO-P,
Type ACT20X-2HDI-2SDO-RNC-S,
Type ACT20X-2HDI-2SDO-RNC-P,
Type ACT20X-2HDI-2SDO-S,
Type ACT20X-2HDI-2SDO-P

For electrical data, refer to the Annex 1.

SPECIFIC CONDITIONS OF USE: YES as shown below:

The NAMUR Pulse Isolator shall be installed in a controlled environment with suitable reduced pollution, limited to pollution degree 2 or better.

The non-intrinsically safe circuits may only be connected to an overvoltage category I or II power source, as defined in IEC 60664-1.

If the NAMUR Pulse Isolator is installed in an explosive atmosphere where equipment protection level Gc is required shall be installed in a suitable enclosure, providing a degree of protection of at least IP54 according to IEC 60079-0.



IECEx Certificate of Conformity

Certificate No.: **IECEx KEM 09.0072X**

Page 4 of 4

Date of issue: 2022-10-28

Issue No: 4

DETAILS OF CERTIFICATE CHANGES (for issues 1 and above)

Assessed per IEC 60079-0 Ed. 7.0, IEC 60079-7 Ed. 5.1, IEC 60079-15 Ed. 5.0

Annex:

[226311500-3-ExTR09.0087.04-Annex1.pdf](#)

Description

The NAMUR Pulse Isolators for rail mounting, Type ACT20X-.HDI-.SDO-...-S (screw terminal) and Type ACT20X-.HDI-.SDO-...-P (push terminal), are 24 V powered, isolating barriers, interfacing "Namur" sensors or contacts located in an explosive atmosphere.

ACT20X-HDI-SDO-...-S and ACT20X-HDI-SDO-...-P are one channel versions.
ACT20X-2HDI-2SDO-...-S and ACT20X-2HDI-2SDO-...-P are two channel versions.

Ambient temperature range -20 °C to +60 °C.

Electrical data

Supply (terminals 51, 52): $U = 19.2 \dots 31.2 \text{ Vdc}$

Digital outputs (terminals 41, 42 and 43, 44):

Transistor output, $U_{\max} = 30 \text{ Vdc}$, $I_{\max} = 80 \text{ mA}$ (Type ACT20X-HDI-SDO-...-S and Type ACT20X-HDI-SDO-...-P)

Relay contacts, $U_{\max} = 30 \text{ Vdc}$ or 32 Vac , $I_{\max} = 2 \text{ A}$ (Types ACT20X-.HDI-.SDO-...-S and Types ACT20X-.HDI-.SDO-...-P)

If the Pulse Isolator is installed outside the hazardous area, the following data for the relay contacts apply:
 $U \leq 30 \text{ Vdc}$ or 250 Vac , $I \leq 2 \text{ Adc}$ or Aac respectively.

Status output (terminals 53, 54):

Relay contacts, $U \leq 32 \text{ Vdc}$ or 32 Vac , $I \leq 1 \text{ Adc}$ or $I \leq 0.5 \text{ Aac}$ respectively.

If the Pulse Isolator is installed outside the hazardous area, the following data for the relay contacts apply:
 $U \leq 110 \text{ Vdc}$ or 125 Vac , $I \leq 0.3 \text{ Adc}$ or $I \leq 0.5 \text{ Aac}$ respectively.

For all circuits above: $U_m = 253 \text{ Vac}$ (max. frequency 400 Hz).

Sensor circuits (terminals 11 ... 14, 21 ... 24):

in type of protection intrinsic safety Ex ia IIC/IIB/IIA/IIIC/I, with following maximum values:

$U_o = 10.6 \text{ V}$; $I_o = 12 \text{ mA}$; $P_o = 32 \text{ mW}$;

$C_o = 2.0 \mu\text{F}$ (IIC) or $6.0 \mu\text{F}$ (IIB) or $18.0 \mu\text{F}$ (IIA) or $90 \mu\text{F}$ (I);

$L_o = 260 \text{ mH}$ (IIC) or 780 mH (IIB) or 1000 mH (IIA) or 1000 mH (I);

$L_o/R_o = 1150 \mu\text{H}/\Omega$ (all groups);

For group IIIC, the parameters of group IIB apply.

The intrinsically safe sensor circuits are infallibly galvanically isolated from each other and from the non-intrinsically safe circuits.